

LP[®] SmartSide[®] Soffit and Rated Sheathing/Ceiling Deck Louisiana-Pacific Corporation

PR-N117

Revised June 20, 2023

Product: LP® SmartSide® Soffit and Rated Sheathing/Ceiling Deck Louisiana-Pacific Corporation, 1610 West End Ave, Suite 200, Nashville, TN 37203 (888) 820-0325

www.lpcorp.com

1. Basis of the product report:

- 2021, 2018, 2015, and 2012 International Building Code (IBC): Section 104.11 Alternative materials
- 2021, 2018, 2015, and 2012 International Residential Code (IRC): Section R104.11 Alternative materials
- DOC PS 2-18 Performance Standard for Wood Structural Panels
- APA PRP-108 Performance Standards and Qualification Policy for Wood Structural Panels
- 2021, 2015, and 2008 ANSI/AWC Special Design Provisions for Wind and Seismic (SDPWS) recognized in the 2021, 2018 and 2015, and 2012 IBC, respectively.
- ASCE 7-16 and ASCE 7-10 Minimum Design Loads for Buildings and Other Structures
- APA Reports T92Q-17, T92Q-22, T94Q-17, T2000Q-21, T2007P-37, T2015Q-40, and T2015Q-41, and other qualification data

Product description:

Louisiana-Pacific Corporation SmartSide® Soffit and Rated Sheathing/Ceiling Deck panels are made with strands of various wood species and strand classifications in accordance with the in-plant manufacturing standard approved by APA, overlaid with a resin-treated paper, and available with either a smooth or embossed surface texture. LP SmartSide Soffit and Rated Sheathing/Ceiling Deck panels are available in 3/8, 7/16, and 19/32 Performance Categories. They are available as 4x8-foot or 4x9-foot panels or cut to 12, 16, or 24-inch widths, and in lengths up to 16 feet. The panels are treated with Zinc Borate for fungal decay and termite resistance. The efficacy of the preservative treatment is outside the scope of this report and the APA certification program. The soffit panels are intended for use as closed soffits at a 24 o.c. Span Rating with the panel strength axis perpendicular to supports. The Rated Sheathing/Ceiling Deck panels are intended for use as open soffits at a 24/16 Span Rating with the panel strength axis perpendicular to supports.

Vented soffit products are available in a 3/8 Performance Category, widths of 8, 12, 16, or 24 inches, and 16 feet in length. Refer to the manufacturer's application instructions for details on the configuration of the vented soffits products.

3. Design properties:

Design wind loads for vented and non-vented LP SmartSide Soffit products are listed in Tables 1 and 2 based on the design procedures in ASCE 7-10 and ASCE 7-16, respectively.

Product installation:

LP SmartSide Soffit and Rated Sheathing/Ceiling Deck shall be installed in accordance with the recommendations provided by the manufacturer (https://lpcorp.com/resources/product-literature/installation-instructions/lp-smartside-soffit) and APA Engineered Wood Construction Guide, Form E30 (www.apawood.org/resource-library). The maximum span shall be in accordance with the Span Rating shown in the trademark for the intended application.

5. Fire-resistant construction:

Wood structural panels that are not fire-retardant-treated have been shown to meet Class III (or C) category for flame spread. Unless otherwise specified, fire-resistant construction shall be in accordance with the recommendations provided in APA *Fire-Rated Systems*, Form W305 (see link above). Vented soffit products have not been evaluated for fire rating.

Limitations:

- a) LP SmartSide Soffit panels shall be used only as closed soffits at a 24 inches o.c. Span Rating with the panel strength axis perpendicular to supports.
- b) LP SmartSide Rated Sheathing/Ceiling Deck panels shall be used only for open soffits or sheathing at a 24/16 Span Rating (refer to trademark) with the panel strength axis perpendicular to supports.
- c) LP SmartSide Soffit must be finished in accordance with recommendations provided by the manufacturer and APA *Engineered Wood Construction Guide*, Form E30 (see links above).
- d) LP SmartSide Soffit and Rated Sheathing/Ceiling Deck panels are produced at Louisiana-Pacific Corporation facilities in Dawson Creek, BC, Hayward, WI, Houlton, ME, Newberry, MI, Tomahawk, WI, Two Harbors, MN, Sagola, MI, and Swan Valley, MB under a quality assurance program audited by APA. The efficacy of the preservative treatment is outside the scope of this report and the APA certification program.
- e) This report is subject to re-examination in one year.

7. Identification:

LP SmartSide Soffit and Rated Sheathing/Ceiling Deck panels described in this report are identified by a label bearing the manufacturer's name (Louisiana-Pacific Corporation) and/or trademark, the APA assigned plant number (402 for the Dawson Creek, BC plant, 357 for the Hayward, WI plant, 368 for the Houlton, ME plant, 416 for the Newberry, MI plant, 435 for the Tomahawk, WI plant, 399 for the Two Harbors, MN plant, 407 for the Sagola, MI plant, or 457 for the Swan Valley, MB plant), the product Performance Category, the Span Rating, the Exposure Rating, the APA logo, the report number PR-N117, and a means of identifying the date of manufacture.

Table 1. Maximum V_{asd} for vented^(a) & non-vented LP® SmartSide Soffit^(b)

	,	50210) · · · · · · · · · · · · · · · · · · ·	,				
:	,	Support	Panel Na	Panel Nail Spacing	:	_	Maximum V _{asd^(e)} (mph)	
Minimum Nail Size ^(c)	Performance	Spacing ^(d)	Edges	Field	Maximum Allowable Wind Pressure (psf)	\	Wind Exposure Category	ý
		(jn.)	(in. o.c.)	(in. o.c.)		В	0	О
			C.	12	31	110	06	85
xoq p9		<u>o</u>	o	9	62	150	130	120
(0.099" x 2.0")		Č	ú	12	21	06	NP(f)	NP ^(f)
	3/8	47	0	9	42	130	110	100
	2	16	9	12	46	130	110	105
8d box		<u>o</u>	0	9	92	170	150	150
(0.113" x 2.5")		70	9	12	31	110	06	85
		4	0	9	69	150	130	120
		16	9	12	45	130	110	105
8d box	77.6	<u>o</u>	0	9	68	170	150	145
(0.113" x 2.5")	01//	70	9	12	30	110	06	85
		47	0	9	69	150	130	120
		16	9	12	41	130	110	100
8d box		2	o	9	82	170	150	140
(0.113" x 2.5")		70	9	12	27	105	06	$NP^{(t)}$
	10/32	74	0	9	22	150	125	110
	18/32	76	9	12	28	150	130	120
10d box		<u>o</u>	0	9	116	170	170	150
(0.128" x 3.0")		70	9	12	39	125	105	06
		4	o	9	77	170	150	130
	0 00 17		-1					

For **SI**: 1 inch = 25.4 mm, 1 psf = 47.88 Pa, 1 mph = 0.447 m/s.

⁽a) Available vented area of 5 inches² per lineal foot of soffit or 10 inches² per lineal foot of soffit.

⁽a)

<u>ပ</u>

Ð

Panels shall be applied with strength axis across supports.

Fasteners shall be a hot-dip galvanized (ASTM A153) or equivalent, plain (smooth) shank nails. Fastener dimensions are as specified in ASTM F1667. Supporting framing must have a minimum specific gravity of 0.42.

Three-second-gust; based on wind pressures acting toward and away from building surfaces, at 30-ft height in Zone 5 with smallest effective area in accordance with Chapter 26 of ASCE 7-10 and Section R301.2.1 of the 2012 IRC. (e)

Not permitted.

Table 2. Maximum V_{ult} or V for vented^(a) & non-vented LP^{\circledcirc} SmartSide Soffit^(b)

GEORGE: MEANINGING	ant of 10 to 100		i 50	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,				
:	,	Support	Panel Na	Panel Nail Spacing		_	Maximum V_{ult} or $V^{(e)}$ (mph)	(hdı
Minimum Nail Size(c)	Performance	Spacing ^(d)	Edges	Field	Wind Pressure (psf)		Wind Exposure Category	ory
		(jn.)	(in. o.c.)	(in. o.c.)		В	0	Q
		Ž	C.	12	52	140	120	110
xoq p9		<u>o</u>	0	9	104	200(f)	160	160
(0.099" x 2.0")		70	9	12	35	115	(6) dN	(B) dN
	3/8	47	0	9	69	160	140	130
))	97	ú	12	77	160	150	130
8d box		<u>o</u>	0	9	153	200(f)	200 ^(f)	180
(0.113" x 2.5")		Č	U	12	51	140	120	110
		4	0	9	66	200	160	150
		97	Ú	12	74	160	140	130
8d box	27.0	<u>0</u>	0	9	149	200(f)	200 ^(f)	180
(0.113" x 2.5")	017	70	9	12	90	140	120	110
		47	0	9	66	200(f)	160	150
		16	9	12	69	160	140	130
8d box		<u>o</u>	0	9	137	200(f)	200(f)	180
(0.113" x 2.5")		70	9	12	46	130	115	(6) dN
	10/22	4	o	9	92	180	160	150
	18/32	7	y	12	96	180	160	150
10d box		<u>o</u>	0	9	193	200(f)	200(f)	200(f)
(0.128" x 3.0")		70	9	12	64	160	130	120
		4	o	9	128	200 ^(f)	180	160
7 10 - 1 10 1	0 27 - 3 1	7 1 1	77.7					

For **SI**: 1 inch = 25.4 mm, 1 psf = 47.88 Pa, 1 mph = 0.447 m/s.

Available vented area of 5 inches² per linear foot of soffit or 10 inches² per lineal foot of soffit. (a)

(a)

Panels shall be applied with strength axis across supports. Fastener dimensions are as specified in ASTM F1667. © ©

Supporting framing must have a minimum specific gravity of 0.42.
Wind pressures acting toward and away from building surfaces, at 30-ft height in Zone 5 with smallest effective area per Chapter 26 of ASCE 7-16 and ASCE 7-10, Section R301.2.1 of the 2021, 2018, and 2015 IRC, and Section 1609.1.1 of the 2021 through 2012 IBC.
Table R301.2.1(1) of the 2021 IRC and Table R301.2(2) of the 2018 and 2015 IRC is limited to a maximum ultimate design wind speed, Vult, of 180 mph. (e)

€

Not permitted

APA – The Engineered Wood Association is an approved national standards developer accredited by American National Standards Institute (ANSI). APA publishes ANSI standards and Voluntary Product Standards for wood structural panels and engineered wood products. APA is an accredited certification body under ISO/IEC 17065 by Standards Council of Canada (SCC), an accredited inspection agency under ISO/IEC 17020 by International Code Council (ICC) International Accreditation Service (IAS), and an accredited testing organization under ISO/IEC 17025 by IAS. APA is also an approved Product Certification Agency, Testing Laboratory, Quality Assurance Entity, Validation Entity, and Product Evaluation Entity by the State of Florida, and an approved testing laboratory by City of Los Angeles.

APA - THE ENGINEERED WOOD ASSOCIATION

HEADQUARTERS

7011 So. 19th St. • Tacoma, Washington 98466 Phone: (253) 565-6600 • Fax: (253) 565-7265 • Internet Address: <u>www.apawood.org</u>

PRODUCT SUPPORT HELP DESK

(253) 620-7400 • E-mail Address: help@apawood.org

DISCLAIMER

APA Product Report® is a trademark of APA – The Engineered Wood Association, Tacoma, Washington. The information contained herein is based on the product evaluation in accordance with the references noted in this report. Neither APA, nor its members make any warranty, expressed or implied, or assume any legal liability or responsibility for the use, application of, and/or reference to opinions, findings, conclusions, or recommendations included in this report. Consult your local jurisdiction or design professional to assure compliance with code, construction, and performance requirements. Because APA has no control over quality of workmanship or the conditions under which engineered wood products are used, it cannot accept responsibility for product performance or designs as actually constructed.